



SAFETY NOTICE


powerCON® TRUE1

Please regularly check the condition of your powerCON TRUE1 connector system (cable connector & chassis) for clear signs of wear and tear.

Through improper use and the excessive use of force, the encoding lugs and guide slots in the connector system can become so severely worn or damaged that it is possible to insert the cable connector the wrong way. However, when inserted the wrong way, the cable connector should not twist-lock into place.

A cable connector inserted the wrong way could, in some circumstances, lead to contact between live wires and the grounding contact in the plug socket.

To determine that the cable connector is inserted correctly, follow the use instructions and listen for the "click" when performing the twist-lock. Immediately unplug any connector that does not twist-lock correctly in place.




Note: When connecting, match the notch on the cable connector to the corresponding guide slot on the chassis.

Note: After inserting properly as in illustration **A**, twist the cable connector clockwise to lock.

Note: The proper twist-lock is achieved when the yellow tab is in the position shown in **C** and an audible «click» is heard.





SAFETY WARNING

Incorrect insertion may cause electrical contact misalignment resulting in equipment malfunction and/or personal injury.

NEUTRIK AG	LI	T: +423 / 237 24 24	F: +423/232 53 93	NEUTRIK France	FR	T: +33 1/4131 6750	F: +33 1/4131 0511
NEUTRIK USA Inc.	USA	T: +1 704 / 972 3050	F: +1 704/438 9202	NEUTRIK Tokyo Ltd.	JP	T: +81 3/3663 4733	F: +81 3/3663 4796
NEUTRIK (UK) Ltd.	UK	T: +44 1983 / 811 441	F: +44 1983/811 439	NEUTRIK Hong Kong Ltd.	HK	T: +852/2687 6055	F: +852/2687 6052
NEUTRIK Vertriebs GmbH	DE/NL/AT/DK	T: +49 8131 / 280 890	F: +49 8131/280 830	NEUTRIK India Pvt. Ltd.	IND	T: +91/982 05 43 424	F: +91/22 26163 540

Nr.: BDA 533 | Date: 20.12.2017 | Data subject to change without prior notice. ©2017 NEUTRIK®. ALL RIGHTS RESERVED. NEUTRIK® is a registered trademark.



SAFETY NOTICE

powerCON® TRUE1

A



Note: When connecting, match the notch on the cable connector to the corresponding guide slot on the chassis.

max. 1 Newton



B



Note: After inserting properly as in illustration A, twist the cable connector clockwise to lock.

C



Note: The proper twist-lock is achieved when the yellow tab is in the position shown in C and an audible «click» is heard.



SAFETY WARNING

Incorrect insertion may cause electrical contact misalignment resulting in equipment malfunction and/or personal injury.

A



Note: When connecting, match the notch on the cable connector to the corresponding guide slot on the chassis.

max. 1 Newton



B



Note: After inserting properly as in illustration A, twist the cable connector clockwise to lock.

C



Note: The proper twist-lock is achieved when the yellow tab is in the position shown in C and an audible «click» is heard.



SAFETY WARNING

Incorrect insertion may cause electrical contact misalignment resulting in equipment malfunction and/or personal injury.

NEUTRIK AG
NEUTRIK USA Inc.
NEUTRIK (UK) Ltd.
NEUTRIK Vertriebs GmbH

LI
USA
UK
DE/NL/AT/DK

T: +423/237 24 24
T: +1 704/972 3050
T: +44 1983/811 441
T: +49 8131/280 890
F: +423/232 53 93
F: +1 704/438 9202
F: +44 1983/811 439
F: +49 8131/280 830

NEUTRIK France
NEUTRIK Tokyo Ltd.
NEUTRIK Hong Kong Ltd.
NEUTRIK India Pvt. Ltd.

FR
JP
HK
IND

T: +33 1/4131 6750
T: +81 3/3663 4733
T: +852/2687 6055
T: +91/982 05 43 424
F: +33 1/4131 0511
F: +81 3/3663 4796
F: +852/2687 6052
F: +91/22 26163 540

Nr.: BDA 533 | Date: 20.12.2017 | Data subject to change without prior notice. ©2017 NEUTRIK®. ALL RIGHTS RESERVED. NEUTRIK® is a registered trademark.